

Secretary of State
Filing Data

**For Filing Administrative
Regulations**

For Emergency
Regulations Only

Effective Date

Expiration Date

Governor's Signature

State Environmental Commission

Classification Proposed Adopted By Agency Temporary Emergency Permanent

Regulation R190-08: [BART] Best Available Retrofit Technology & Emission Limitations for Major Electric Generating Units: This regulation would add a requirement for certain electric generating units to install best available retrofit technology and comply with emission limitations for NOx, SO2 and PM10. These requirements apply to Nevada Energy's Fort Churchill and Tracy Generating Stations in the Mason Valley and the Truckee River Basins, respectively; as well as Nevada Energy's Reid Gardner Generating Station in the California Wash northeast of Las Vegas; and Southern California Edison's Mohave Generating Station near Laughlin. This proposed regulation is necessary to comply with the federal Regional Haze Regulations promulgated in July 1999 (64FR35714). (SEC P2008-15)

Authority citation other than 233B: §§1-7, NRS 445B.210.

Notice date: January 9, 2009

Hearing date: February 11, 2009